



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-196-09**

Valid from: 2022 04 27  
until: 2024 04 27

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Socket-outlets for appliances with side earthing contacts**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VAEE 38186**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*

Digitally signed by T. Neumayer  
Email=[t.neumayer@ove.at](mailto:t.neumayer@ove.at)

Dipl.-Ing. T. Neumayer

Wien, 2022 03 01



## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

PCE Lanka (Private) Limited  
No.76 Kandahena Estate, Artigala Road  
Panaluwa, Watareka  
10504 Padukka  
Sri Lanka

**Tested and certified according to:**

ÖVE/ÖNORM IEC 60884-1:2005-09-01  
ÖVE/ÖNORM E 8684-1:2010-03-01  
ÖVE/ÖNORM E 8684-2-2:2010-03-01 (only for types without sealing bulge)  
Beschluss IS 248 (only for types with sealing bulge)

**Product: Socket-outlets for appliances with side earthing contacts**

**Type designation:**

**Rating:**

**Trademark:**

**1050...**

Rated voltage: AC 250 V  
Rated current: 16 A  
IP 54, screwed contacts  
without sealing bulge  
for fixed application  
see typecode

PCE / ELCEE / METECEE

**1050...w**


Rated voltage: AC 250 V  
Rated current: 16 A  
IP 54, screwed contacts  
with sealing bulge  
for portable application  
see typecode

PCE / ELCEE / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**Typecode for Serie 1050 (one piece design):**



**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.